

RECEIPT OF ADDENDUM ACKNOWLEDGEMENT

ADDENDUM NO. 4

TO

BID DOCUMENTS FOR
POOKELA WELL "B" – DEVELOPMENT
JOB NO. 15-05A

Please acknowledge the receipt of the above **ADDENDUM** issued by the Department of Water Supply, County of Maui, by signature and recording the date of receipt below.

Bidder: _____

Authorized Signatory: _____ Date: _____

NOTE: This form may be FAXED to the Engineering Division at (808) 270-7833.

ADDENDUM NO. 4

**TO THE
BID DOCUMENTS
FOR**

**POOKELA WELL "B" – DEVELOPMENT
JOB NO. 15-05A**

NOVEMBER 1, 2019

Contractors preparing bids are hereby notified of the following revisions and additions to the project plans and specifications. These changes will govern the work and take precedence over previously issued plans and specifications governing the items mentioned.

BID OPENING DATE

The following amendment shall be made to the NOTICE TO BIDDERS:

"The bid opening date shall be **Thursday, November 7, 2019 at 2:00 pm HST.**"

SPECIFICATION REVISIONS

1. Specification 15131 Submersible Vertical Turbine Deep Well Pumping Unit

- a. Paragraph 1.3F Certifications, DELETE subsection 4. ADD the following:

"4. The motor shall be NSF-61 and ISO 9001 certified and the pump (without coatings) shall be NSF-61 and ISO 9001 compliant."

- b. Paragraph 1.4 Supplier Qualifications, DELETE subsection B. ADD the following:

"The pump manufacturer/supplier has overall responsibility to supply the pumping unit (submersible pump, submersible motor, column pipe, column couplings, check valves, discharge head (elbow), cables, and related instrumentation and accessories) that meet the requirements of this specification. The pump manufacturer/supplier may obtain the column pipe and column couplings from a second party vendor. During start-up, installation, and performance evaluation, the pump installer is the sole responsible party. A representative from the pump manufacturer/supplier shall be present during start-up, installation, and performance evaluation."

- c. Paragraph 2.1.B.7 Pumping Unit Test Requirements, DELETE subsection a. ADD the following:

- a. Minimum guaranteed
pumping unit overall
(wire-to-water) efficiency at
rated capacity and head: 66 percent (66%)

