

FURNISH AND DELIVER

ONE (1) 350 HORSE POWER MOTOR

FOR THE DEPARTMENT OF WATER SUPPLY

COUNTY OF MAUI

FORMAL BID

JOB NO. IFB # DWSP 2013-05

INVITATION TO BIDDERS


JOB NO. IFB # DWSP 2013-05

Pursuant to Chapter 103-D, HRS, sealed offers shall be received up to and be publicly opened at 10:00 o'clock a.m. on NOVEMBER 14, 2012, by the Fiscal Division, Purchasing Branch, Department of Water Supply, 5th Floor, Kalana O Maui (County Building), 200 South High Street, Wailuku, Maui, Hawaii, 96793, to:

FURNISH AND DELIVER ONE (1) 350 HORSE POWER MOTOR

Specifications and Offer Form may be obtained at the Office of the Purchasing Agent, Fiscal Division, located on the fifth floor of the County Building. Office hours are 8:00 a.m. to 4:00 p.m., Monday thru Friday, or visit the Maui County website: www.mauicounty.gov, under Bids & Proposal/Goods and Services.

Bidders are required to comply with the newest procurement code, HRS, Chapter 103-D, any rules and regulations and policy directives issued with respects to Chapter 103-D and any amendments.



DANILO F. AGSALOG
Director of Finance
County of Maui

SPECIAL PROVISIONS

JOB NO. IFB DWSP# 2013-05

1. To furnish and deliver one (1), 350 horse power motor for the Department of Water Supply, County of Maui, shall be subject to the Minimum Specifications, Special Provisions, Offer Form and General Conditions (bid documents).
2. Offer shall include all applicable taxes, except Federal Excise Tax from which the County is exempt, and freight/delivery charges F.O.B. Department of Water Supply, County of Maui at 614 Palapala Drive in Kahului, Maui.
3. Bidder shall complete the offer form, enclosing current literature describing the 350 horse power motor.
4. The Director reserves the right-
 - a. to accept or reject any or all offers and to waive any minor or inadvertent discrepancy in the bid documents.
 - b. to withhold award of contract for a period of thirty (30) calendar days from the date of bid opening; and,
 - c. to increase or decrease the quantities anytime prior from the charges.
5. Manufacturer's brands and stock/part numbers specified, does not denote a preference for that make, but specify the level of quality desired. Alternate brands found to be equal to or greater in quality to the brand specified may be acceptable by the Officer-In-Charge, however the burden to prove equality shall rest with the offer.
6. Delivery date shall be computed from the Official Commencement Date as specified in the "Notice to Proceed" issued by the Director.
7. A contract shall be awarded to the lowest responsible and responsive bidder, based on the TOTAL OF THE OUT RIGHT PURCHASE.
8. A bid bond and performance bond shall not be required.
9. No offer shall be withdrawn after the hour set for the bid opening.
10. Bidder shall deposit sealed offer with the Bid Receiver, Division.

11. Bidder must be a factory authorized dealer and service center.
12. Bidder shall deposit sealed offer with the Bid Receiver, Fiscal Division, Purchasing Branch, Department of Water Supply, located on the 5th Floor of the County Building at 200 South High Street, Wailuku, Maui 96793. Faxed offers shall be rejected.
13. Any questions pertaining to the technical aspect of this solicitation shall be directed to Ryan Hedani: Telephone (808) 870-3606.

Any questions pertaining to the solicitation shall be directed to Ken Bissen Jr., Purchasing Specialist: Telephone (808) 270-7684 or Fax (808) 270-7136.

Any acceptable modifications or clarifications shall be made by issuance of an addendum, shall be given by written notice to all parties.

14. Offers must be in hand by 10:00 o'clock a.m. on the date designated for the bid opening. Offers mailed and postmarked earlier than the date and time specified, but received later shall be rejected. Offers received and time stamped earlier at other locations, but received by the bid receiver later than the date and time specified, shall be rejected.
15. As a prerequisite for entering into a contract Bidders shall submit a current Tax Clearance, Certificate, Certificate of Good Standing, and Certificate of Compliance by using the Hawaii Compliance Express, which allows businesses to register online through a simple wizard interface at:

<http://vendors.ehawaii.gov/hce/splash/welcome.html>

Bidders registered with Hawaii Compliance Express may submit a one-page printout from the Hawaii Compliance Express website.

16. INVOICING: The certificate of compliance from the Hawaii Compliance Express will be attached with the final payment.
17. For Terms and Conditions for Goods and Service go to: www.mauicounty.gov/department/Finance/purchasing. Look for Purchasing Terms and Conditions, Goods and Services.
18. The bidder will supply five (5) each, five (5) gallon drums of synthetic oil, for above motor bearings, on or before the delivery of motor.

OFFER FORM

JOB NO. IFB# DWSP 2013-05

Director of Water Supply
County of Maui
Wailuku, Maui, Hawaii

Dear Sir:

I agree to furnish, deliver and sell outright to the Department of Water Supply of the County of Maui, F.O.B. to NASKA base yard at 614 Palapala Drive, Kahului, Maui, all in strict compliance with the Special Provisions, Minimum Specifications, General Conditions and Offer Form, the following:

FURNISH, DELIVER ONE (1) 350 HORSE POWER MOTOR

TOTAL OUTRIGHT PRICE \$ _____

DELIVERY WILL BE MADE IN 120 CALENDAR DAYS OR LESS FROM "NOTICE TO PROCEED" ISSUED BY THE DIRECTOR OF WATER SUPPLY.

It is understood and agreed that if a contract is awarded, the undersigned shall enter into and execute a contract for the faithful delivery of the One (1) 350 Horse Power Motor.

MINIMUM SPECIFICATION

350 HORSEPOWER MOTOR

New Motor Replacement Bid:

VERTICAL SOLID SHAFT

Horsepower: 350

Voltage: 460

Amps: 388

RPM: 1780

Phase: 3

Premium Efficient

Enclosure: TEFC

Poles: 4

Frame: 449VPH

Service Factor: 1.15

Insulation Class: Class "F"; VPI 1000

Altitude in feet (Max): 3300 FT.

Ambient Degree C (Max): +40C

Application: Centrifugal pump

Base Diameter: 20"

Customer Down Thrust (lbs.): 175% Extra High Thrust

Duty Cycle: Continuous duty

Direct-on-line start

115 volt heaters, both top and bottom

Conduit (motor leads) box opening size: 4" NPT

1 conduit openings- bottom of conduit box

Motor windings over temperature switch

Motor must be same as specifications given below:

Make: U.S. Motors

CAT.#: 20084061-100

I.D. #: P0920084061-0001 R0001

Bearings: 7226-BCB Q2 / 6219-JC3

VENDOR MUST PROVIDE AND SUBMIT DOCUMENTS OF THE 350 HP MOTOR TO THE DEPARTMENT OF WATER FOR APPROVAL PRIOR TO ORDERING THE MOTOR.